

The floor plan shows the following departments and areas:

- Top Row (Left to Right):**
 - ufficio PESA
 - ufficio CONTROLLO PROCESSO
 - ufficio TECNICO
 - INGRESSO
 - ufficio SEGRETERIA
 - ufficio AMMISTRAZIONE
 - INFERMERIA
 - SERVIZI DONNE
 - AREA ADDETTI
- Second Row (Left to Right):**
 - atrio
 - corridoio di servizio
 - LOCALE ARCHIVIO
 - LOCALE TECNICO
 - SERVIZI UOMINI
 - LOC. Q.E.
- Bottom Row (Left to Right):**
 - ufficio ANALISI LABORATORIO
 - W.C. F. H/M
 - SALA RIUNIONI
 - UFFICIO DIRETTORE
 - W.C. F. H/M
 - W.C. F. H/M
 - W.C. F. H/M

The plan includes numerous red square and circular markers, some with the letter 'E', indicating specific points of interest or equipment locations throughout the facility.

The diagram illustrates the vertical dimensions of a staircase, showing various heights and clearances in centimeters. The dimensions are as follows:

- Staircase (Scala):**
 - Overall height: 205 cm
 - Clearance (distanza) to the ceiling: > 225 cm
 - Height from the floor to the bottom of the stairs: 180 cm
- Handrail (Presa a corrimano ferro spigolato verniciato):**
 - Height from the floor: 120 cm
 - Height from the floor to the top of the handrail: 115 cm
- Handrail (Presa a corrimano ferro elaborato verniciato parte superiore):**
 - Height from the floor: 100 cm
- Handrail (Presa a corrimano ferro elaborato verniciato parte inferiore):**
 - Height from the floor: 80 cm
 - Height from the floor to the top of the handrail: 70 cm
- Staircase (Scala):**
 - Height from the floor to the top of the stairs: > 175 cm
- Staircase (Scala):**
 - Height from the floor to the top of the stairs: > 7 cm
- Staircase (Scala):**
 - Height from the floor to the top of the stairs: > 4 cm

Disano 885 compact

145

Ø230 126

BBS COMPACT

WARNING: Read the instruction manual carefully before installation and use. Failure to follow the instructions may result in injury or damage.

CAUTION: The system is designed for outdoor use only. It must be installed in a dry, well-ventilated area. Do not touch the internal components.

INSTALLATION: Follow the provided wiring diagram. Ensure all connections are secure and insulated. The system must be grounded according to local regulations.

OPERATION: The system will automatically turn on at dusk and off at dawn. It can also be controlled via a remote control or a photocell sensor.

Acc.600 XR-EM

SYSTEM COMPONENTS:

- BATTERY
- INVERTER
- CHARGER
- LED DIMMING

WIRING DIAGRAM:

The diagram shows the connection between the Battery, Inverter, Charger, and LED Dimming unit. It includes terminals for Power+, Power-, Ground, and Data+/-.

BBS COMPACT

Dimm 1-10V or DALI

ON - OFF

Wiring Details:

- Power+: Connect to the positive terminal of the battery.
- Power-: Connect to the negative terminal of the battery.
- Ground: Connect to a common ground point.
- Data+: Connect to the dimmer control wire.
- Data-: Connect to the dimmer control wire.

BBS COMPACT DARK 2-GND

Wiring Details:

- Power+: Connect to the positive terminal of the battery.
- Power-: Connect to the negative terminal of the battery.
- Ground: Connect to a common ground point.

Technical Specifications:

- Model: BBS COMPACT
- Power Consumption: 10W
- Beam Angle: 120°
- Material: Aluminum
- Color: Black
- Weight: 1.5 kg
- Dimensions: 145 x 230 x 126 mm

[illegible][illegible][illegible]

	Disano 957 Eco - bilampada LED - High Performance Disano 957 69W CLD CELL grigio
	Disano 957 Eco - bilampada LED - High Performance Disano 957 69W CLD CELL-EMERGENZA
	Disano 832 Rodi Disano 832 LED CLD CELL bianco
	Disano 832 Rodi Disano 832 LED CLD CELL-EMERGENZA
	Disano 1395 Cilindro a sospensione - COB Disano 1395 LED CLD CELL grigio207
	Disano 885 Compact Dark 2 - SMD - UGR-19 Disano 885 SMD 14W CLD CELL bianco
	Disano 885 Compact Dark 2 - SMD - UGR-19 Disano 885 SMD 14W CLD CELL EMERGENZA
	Disano 854 Heron - UGR-19 Disano 854 LED 28W CLD CELL bianco
	Disano 854 Heron - UGR-19 Disano 854 LED 28W CLD CELL EMERGENZA
	910 HEALT CLD CELL LED 2640lm-4000K CRI 90 22W
	910 HEALT CLD CELL - E LED 2640lm-4000K CRI 90 22W

	INTERUTTORE UNIPOLARE
	PULSANTE UNIPOLARE
LEGENDA SIMBOLI FORZA MOTRICE	
	PRESSA BIPASSO 2P+T 250VA
	PRESSA LINEEL 2P+T 1000VA
	PRESSA BIPASSO 2P+T 1010VA P65
	PRESSA LINEEL 2P+T 1000VA P65
IMPIANTO RILEVAZIONE INCENDI	
	CENTRALE RILEVAZIONE INCENDI
	ALIMENTATORE IMPIANTO RILEVAZIONE INCENDI
	PULSANTE DI SEGNALAZIONE MANUALE ALLARME INCENDIO A ROTTURA VETRO
	PULSANTE DI SEGNALAZIONE MANUALE ALLARME INCENDIO A ROTTURA VETRO
	GEMMA IMPIETTOZIONE STATO RILEVATORE INSTALLATA IN AMBIENTE
	RILEVATORE OTTICO SI FUMO, COMPLETO DI BASE, INSTALLATO IN AMBIENTE
	RILEVATORE OTTICO SI FUMO, COMPLETO DI BASE, INSTALLATO CONTROSPICCHETTO
AREA DI COPERTURA RILEVATORE OTTICO DI FUMO (RAGGIO DI COPERTURA 6,5m)	
	TARGA OTTICO-ACUSTICA IP42
	SIRENA ALLARME INCENDIO CON LAMPEGGANTE
IMPIANTO TRASMISSIONE DATI	
	RACK 1P 48P ARCHITETTURA IMPIANTO TRASMISSIONE DATI CON SWITCH 48 PORTE HP PRODUCE V200-4889C
	PRESSA RJ45 MARCA PANDUIT
IMPIANTO TVCC	
	TELECOMBA
	VIDEOSORVEGLIANZA TVCC
IMPIANTO CITOFONICO	
	POSTAZIONE ESTERNA CITOFONICA
	POSTAZIONE INTERNA CITOFONICA (PREDISPOSTA PER UNITA' VIDEO)
	ALIMENTAZIONE E COMANDO ELETTROSICURTURA
	PULSANTE APERTURA



IMPIANTO DI COMPOSTAGGIO DELLA FRAZIONE ORGANICA DA
RACCOLTA DIFFERENZIATA DA REALIZZARE PRESSO
MARIGLIANO (NA)

PROGETTO DEFINITIVO

1097	0	IE	PT	1,5	1	1	DI	1	1:50	.DWG
CONMESSA					REV.			FOGLIO	SCALA	FORMATO

CAPOGRUPPO MANDATARIA	MANDANTE	MANDANTE	IL RESPONSABILE DEL PROCEDIMENTO
-----------------------	----------	----------	----------------------------------

ICARTA S.R.L.
SOCIETÀ DI INGEGNERIA
VIA S. GIUSEPPE 1 - 00187 ROMA (ITALIA)
Tel. 06/478101 - 06/478102 - 06/478103
Fax 06/478104 - 06/478105
E-mail: info@icarta.it
Web: www.icarta.it

ROTISCIANI
 Via...
 Tel. 02...
 E-mail: info@rotisciani.com
 PEC: info@rotisciani.it

GENNAIO 2020	EMISSIONE	AS	VP	GV	VR
--------------	-----------	----	----	----	----

ESAME	DATA	OGGETTO	REDAITTO	VERIFICATO	APPROVATO	AUTORIZZATO
-------	------	---------	----------	------------	-----------	-------------

Vieta il sensi di legge la divulgazione e la riproduzione del presente disegno senza la preventiva autorizzazione